

# CERTIFICATE OF COMPLIANCE

**Certificate Number:** SGSNA/22/GZ/00116

**Contract Number:** 801756  
**Certificate Project Number:** GZ-CERT220400691

**Certified Product:** Hybrid Solar Inverter  
**Trademarks:** **ATLAS**

**Model(s):** ATLAS-X5.0-US, ATLAS-X6.0-US, ATLAS-X7.6-US, ATLAS-X8.0-US, ATLAS-X10.0-US

**Technical Data:** See page 2

**Certificate Holder:** Atlas Energy Solutions LLC  
848 W 1455 N UNIT 120, 84321, Logan, Utah, United States of America

*This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at [www.sgs.com](http://www.sgs.com) or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:*

UL 1741, Third Edition, Dated September 28, 2021 (including UL 1741 Supplement SB)  
CSA C22.2 No. 107.1:16 (reaffirmed 2021)  
UL 1741 Supplement SA, 2010 Ed.2 Rev Feb. 15, 2018  
UL 1699B, 1st Ed. August 22, 2018

Compliance with IEEE Std 1547:2018 (Revision of IEEE Std 1547:2003), approved 15 February 2018; IEEE Std 1547a™-2020 Approved 9 March 2020. (Refer to IEEE Std 1547.1:2020, approved 5 March 2020.)

Hawaiian Electric Companies, IEEE 1547.1-2020 Source Requirements Document Version 2.0 ("SRD V2.0"), effective on July 1st, 2020

Generating Facility Interconnections- CPUC Rule 21 Effective on Jul 30, 2017

Authorized by:

Effective date: 12 April 2023



Jason Wei  
Certifier



#### Certification Body

Connectivity & Products, a division of SGS North America Inc.  
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA  
t +1 770 570 1800 f +1 770 277 1240 [www.sgs.com](http://www.sgs.com)



# CERTIFICATE OF COMPLIANCE

**Certificate Number:** SGSNA/22/GZ/00116

**Contract Number:** 801756  
**Certificate Project Number:** GZ-CERT220400691

**Technical Data:**

ATLAS-X5.0-US  
PV side: 120-500V(500Vmax), 14A\*4, 22A;  
Batteries side: 40-60V, 120Amax  
AC grid side: 120Vac/240Vac Split phase, 60Hz, 20.8A(22.9Amax),  
-0.8~+0.8  
EPS(\*) side: 120Vac/240Vac, Split phase, 60Hz, 5KVA, 20.8A

ATLAS-X6.0-US  
PV side: 120-500V(500Vmax), 14A\*4, 22A;  
Batteries side: 40-60V, 135Amax  
AC grid side: 120Vac/240Vac Split phase, 60Hz, 25A(27.5Amax),  
-0.8~+0.8  
EPS(\*) side: 120Vac/240Vac, Split phase, 60Hz, 6KVA, 25A

ATLAS-X7.6-US  
PV side: 120-500V(500Vmax), 14A\*4, 22A;  
Batteries side: 40-60V, 190Amax  
AC grid side: 120Vac/240Vac Split phase, 60Hz, 31.7A(35Amax),  
-0.8~+0.8  
EPS(\*) side: 120Vac/240Vac, Split phase, 60Hz, 7.6KVA, 31.7A

ATLAS-X8.0-US  
PV side: 120-500V(500Vmax), 14A\*4, 22A;  
Batteries side: 40-60V, 190Amax  
AC grid side: 120Vac/240Vac Split phase, 60Hz, 33.3A(36.7Amax),  
-0.8~+0.8  
EPS(\*) side: 120Vac/240Vac, Split phase, 60Hz, 8KVA, 33.3A

ATLAS-X10.0-US  
PV side: 120-500V(500Vmax), 14A\*4, 22A;  
Batteries side: 40-60V, 190Amax (for charging), 210Amax  
(for discharging)  
AC grid side: 120Vac/240Vac Split phase, 60Hz, 41.7A(45.8Amax),  
-0.8~+0.8  
EPS(\*) side: 120Vac/240Vac, Split phase, 60Hz, 10KVA, 41.7A

(\*) EPS: Equipment or facilities that deliver electric power to a load

## Certification Body